

General Environmental Incident Summary

Incident: 10539

Notice: 7/27/2020

Occurred: 7/27/2020

DEM Incident No:

No Further Action:

Responsible Party: Cass County Electric Coop

County: Cass

Twp Rng Sec Qtr: 139 49 27

Lat Long + Method: 46.83108 -96.84818 Interpolation from map

Location Description: 4100 32nd Ave S Fargo, ND 58104

Submitted By Info: CJ Erickson
4100 32nd Ave S
FARGO ND 58104

Received By Info:

Contact Info: CJ Erickson
4100 32nd Ave S
FARGO ND 58104

Affected Medium: 03 - soil

Near. Occupied Bldg:

Type of Incident: Utility transformer leak

Release Contained: Yes

Reported to NRC: Unknown

Contaminant: Transformer mineral oil, non-PCB per manufacture stamp on transformer

Volume of Release: 1 gallons

Duration of Release:

Agriculture Related: No

EPA Extremely

Hazardous Substance: Unknown

Number of Fatalities: 0

Number of Injuries: 0

Cause of Incident:

Pre-tested NON-PCB tub started to leak sitting in yard Coop# 11182

Risk Evaluation:

None

Potential Env. Impacts:

None

Action Taken/Planned:

Excavated crushed concrete and soaked up oil with approved oil spill blankets.

Wastes Disposal Location:

Other Agencies Involved:

Updates

Date: 7/27/2020 **Status:** Reviewed - No Action Required

Author: Lund, Dylan

Notes:

According to the incident report, 1 gallon of transformer mineral oil was confined to the concrete yard of the Cass County Electric Coop. No follow-up required.

Updated Volume: None at the time of this update