



## **Updates**

---

**Date:** 5/15/2017      **Status:** Reviewed - No Action Required

**Author:** Martin, Russell

**Notes:**

Talked to Barnes County Emergency Manager and site personnel who were there when the incident occurred. "Empty" nurse tank had been returned to the lot, but a faulty valve on the tank was found to be leaking. Based on it being brought back empty (~1% of product left), only a minimal amount of residual anhydrous ammonia was lost according to site personnel. Fire Department personnel simply shut off the valve on the tank in response, and it was then drained and valve was fixed. A few homes nearby were temporarily evacuated when the vapor was first noted, but evacuation order was lifted shortly thereafter once it was determined it was just a faulty valve. No further follow-up required at this time.

**Updated Volume:** None at the time of this update