

General Environmental Incident Summary

Incident: 5653

Notice: 3/10/2018

Occurred: 3/10/2018 1045

DEM Incident No:

No Further Action:

Responsible Party: CHS - Dakota Plains Ag

County: Cass

Twp Rng Sec Qtr: 137 50 29

Lat Long + Method: 46.64535 -97.01695 Interpolation from map

Location Description: CHS - Dakota Plains Ag, 141 Rustad Drive Kindred ND

Submitted By Info: Verne Wolf

CHS - Dakota Plains Ag

5324 165 ave SE

Kindred ND 58051

Received By Info:

Contact Info: Verne Wolf

5324 165 Ave SE

Kindred ND 58051

Affected Medium: 05 - air and soil

Near. Occupied Bldg: 100 Feet

Type of Incident: Fire

Release Contained: Yes

Reported to NRC: Yes

Contaminant: No chemicals were released, concerned chemicals were diesel and gasoline fuels

Volume of Release: 0

Duration of Release: 4 hours

Agriculture Related: No

EPA Extremely

Hazardous Substance: No

Number of Fatalities: 0

Number of Injuries:

Cause of Incident:

Wood Structural building fire with fuel transport vehicle and pick up inside.

Risk Evaluation:

Fire; Danger to residential community.

Potential Env. Impacts:

Fire and fire related atmospheric smoke from wood structural fire. Frozen ground where fire water was contained. No chemicals or substances were released in fire or emergency response.

Action Taken/Planned:

911 was contacted (Kindred FD, Horace FD, Davenport FD, and Cass country Sheriffs office responded, vehicles were removed from fire. No chemical or substance were released from vehicles. Fire water was disposed through city storm sewer system after city gave approval and water was inspected for any chemical substances.

Wastes Disposal Location:

In an approved demolition disposal facility

Other Agencies Involved:

Local Fire Department, Local Law Enforcement, Local Emergency Manager

Updates

Date: 3/12/2018 ***Status:*** No Further Action Requested

Author: DeVries, Taylor

Notes:

According to the incident report, there were no contaminants released due to a fire. No further follow-up is needed at this time.

Updated Volume: None at the time of this update