

General Environmental Incident Summary

Incident: 5848 **Notice:** 9/13/2018 0900 **Occurred:** 9/12/2018 1400

DEM Incident No:

No Further Action:

Responsible Party: Minnesota Power

County: Oliver

Twp Rng Sec Qtr: 141 86 25

Lat Long + Method: 46.99951 -101.53270 Navigation quality GPS

Location Description: From interstate 94 take exit 120 North for 9 miles turn right on 28th Street and go 3 miles to access Turbine access road and turn right T-28 will be first tower of two on access road

Submitted By Info: Greg Prom
MN Power
30 West Superior Street
Duluth MN 55802

Received By Info:

Contact Info: Greg Prom
30 West Superior Street
Duluth MN 55802

Affected Medium: 03 - soil

Near. Occupied Bldg: 1 Miles

Type of Incident: turbine coolant radiator hose

Release Contained: Yes

Reported to NRC: Unknown

Contaminant: antifreeze

Volume of Release: 5 gallons

Duration of Release:

Agriculture Related: No

EPA Extremely

Hazardous Substance: Unknown

Number of Fatalities: 0

Number of Injuries: 0

Cause of Incident:

Antifreeze released from the nipple on a 2-inch radiator hose

Risk Evaluation:

Minimal to no risk of immediate health hazards because of the type of chemical, limited amount, and outside location of spill.

Potential Env. Impacts:

Since the spill was cleaned up promptly and the spill was antifreeze, this spill should have minimal to no impact to the environment.

Action Taken/Planned:

The antifreeze was absorbed with absorbent pads

Wastes Disposal Location:

Sawyer Landfill

Other Agencies Involved:

Updates

Date: 9/14/2018 **Status:** Reviewed - No Action Required

Author: O'Gorman, Brian

Notes:

According to the report, 5 gallons of antifreeze was released near a wind turbine. Report states that the release was absorbed with absorbent pad and should have minimal to no impact to the environment. No further follow-up needed at this time.

Updated Volume: None at the time of this update