

# General Environmental Incident Summary

**Incident:** 9238

**Notice:** 9/19/2019

**Occurred:** 9/19/2019

**DEM Incident No:**

**No Further Action:**

**Responsible Party:** BRENNNA CONSTRUCTION

**County:** Cass

**Twp Rng Sec Qtr:** 139 49 16

**Lat Long + Method:** 46.85789 -96.86734 Interpolation from map

**Location Description:** 1537 48 ST S  
Fargo, ND 58103  
CCEC location number 103-161-3770 Coop number# 14548

**Submitted By Info:** CJ Erickson  
4100 32nd Ave S  
FARGO ND 58104

**Received By Info:**

**Contact Info:**  
1109 HWY 10  
GLYNDON MN

**Affected Medium:** 03 - soil

**Near. Occupied Bldg:** 1 Feet

**Type of Incident:** Contractor damage

**Release Contained:** Yes

**Reported to NRC:** Unknown

**Contaminant:** Transformer mineral oil, non-PCB per manufacture stamp on transformer

**Volume of Release:** 2 gallons

**Duration of Release:**

**Agriculture Related:** No

**EPA Extremely Hazardous Substance:** Unknown

**Number of Fatalities:** 0

**Number of Injuries:** 0

**Cause of Incident:**

Contractor digging hit underground power line breaking bushing causing approximately 2 gallons of oil to leak

**Risk Evaluation:**

None

**Potential Env. Impacts:**

none, oil contained and cleaned up

**Action Taken/Planned:**

Crew sucked up the oil and cleaned up transformer pad with oil absorbent pads. Oil and clean-up material will be held until oil test verifies this is non-PCB oil.

**Wastes Disposal Location:**

Upon receipt of transformer oil testing, any non-PCB dirt and spill clean-up material will be disposed of at a land fill. If testing identifies the presents of PCB's measures will be taken to ensure disposal of all product is done through Clean Harbors Environmental, Inc., Coffeyville, KS.

**Other Agencies Involved:**

## **Updates**

---

**Date:** 9/19/2019      **Status:** Reviewed - Follow-up Required

**Author:** Crowdus, Kory

**Notes:**

Release from transformer. Follow up is required.

**Updated Volume:** None at the time of this update

---

**Date:** 9/30/2019      **Status:** Correspondence - More Follow-up Required

**Author:** Striebel, Ivana

**Notes:**

9/30/2019 - Made information request of RP, further action needed.

**Updated Volume:** None at the time of this update

---

**Date:** 2/9/2021      **Status:** Correspondence - More Follow-up Required

**Author:** Suess, Bill

**Notes:**

This spill involves non-PCB mineral oil. The Spill Investigation Program will retain oversight.

**Updated Volume:** None at the time of this update

---

**Date:** 4/30/2021      **Status:** Inspection - No Action Required

**Author:** Suess, Bill

**Notes:**

Inspected the site on 4/26/2021. No adverse environmental impacts, associated with this release, were observed. No further action is warranted.

**Updated Volume:** None at the time of this update

---

**Date:** 10/1/2021      **Status:** Correspondence - No Action Required

**Author:** Striebel, Ivana

**Notes:**

10/1/2021 - Received lab analysis for transformer oil, this was a nonPCB release. Results located in incident folder. No further action needed.

**Updated Volume:** None at the time of this update