

General Environmental Incident Summary

Incident: 9303

Notice: 11/6/2019

Occurred: 11/5/2019 1100

DEM Incident No:

No Further Action:

Responsible Party: Central Power Electric Cooperative, Inc.

County: McHenry

Twp Rng Sec Qtr: 153 79 31 SW

Lat Long + Method: 48.01821 -100.87830 Interpolation from map

Location Description: 4224 14th Ave. North-Velva, ND 58790

Submitted By Info: Joel Culbertson
525 20th Ave SW
Minot ND 58701

Received By Info:

Contact Info: Joel Culbertson
525 20th Ave SW
Minot ND 58701

Affected Medium: 03 - soil

Near. Occupied Bldg:

Type of Incident: Tank Leak

Release Contained: Yes

Reported to NRC: Unknown

Contaminant: Mineral Oil

Volume of Release: 5 gallons

Duration of Release:

Agriculture Related: No

EPA Extremely

Hazardous Substance: No

Number of Fatalities:

Number of Injuries:

Cause of Incident:

Oil level site glass leaked on power circuit breaker

Risk Evaluation:

No immediate health hazards

Potential Env. Impacts:

The mineral oil spill was contained within the substation (rock and gravel/soil) and did not reach a navigable waterway.

Action Taken/Planned:

Spill contained within a 30 foot radius of the malfunctioned equipment. The spill was contained within the gravel and rock on the substation's pad. The spill was cleaned up by Strata Corporation and they will take responsibility for properly disposing of the contaminated soil.

Wastes Disposal Location:

Other Agencies Involved:

Updates

Date: 11/6/2019 **Status:** Reviewed - No Action Required

Author: DeVries, Taylor

Notes:

This incident is a duplicate of General Incident #9304, please refer to this incident instead. No Further action needed. This incident will be closed.

Updated Volume: None at the time of this update