



Fuel Product Posting Rules

North Dakota Health Department – Division of Waste Management

Underground Storage Tank Program

Gold Seal Building - 918 E. Divide Ave., 3rd Floor

Phone: 701-328-5166 Fax: 701.328.5200 – Website: www.ndhealth.gov/wm

Revised 12/2014

Gasoline or alcohol-blended gasoline dispensed must have the octane and alcohol blend posted (labeled) on the dispenser's front panel in a type not less than one inch [2.54 centimeters] high.

For alcohol-blended gasoline dispensed that consists of one percent or more by volume of alcohol, the dispenser shall bear the alcohol information. Dispensers posted (labeled) with the information that the alcohol-blended gasoline being dispensed is "Up To 10% Ethanol" must contain between 1% to 11% ethanol by volume or dispensers posted (labeled) with "10% Ethanol" must contain between 9% to 11% ethanol by volume. For higher percentage ethanol labeling requirements, please contact the Department.

Octane and alcohol-blended labels must be posted (labeled) in a position that is clear and conspicuous from the driver's position. Octane of all gasoline or alcohol-blended gasoline offered for retail sale must be at **least** eighty-seven.

No dealer may sell alcohol-blended gasoline unless the dispensing unit AND any price advertising bear the name of the alcohol blended with the gasoline.

Labeled Octane	Minimum Requirement	Posted (labeled) may be
87	86.3	"unleaded"
88	87.3	
89	88.3	"super", "plus", or "midgrade"
89.5	88.8	
90	89.3	"premium", "supreme", or "high test".
91	90.3	
92	91.3	
93	92.3	



The North Dakota Petroleum Product Testing Rules can be found at <http://www.legis.nd.gov/information/acdata/pdf/33-34-01.pdf?20141223154147>

