



## Fuel Product Posting Rules

North Dakota Department of Environmental Quality – Division of Waste Management  
Underground Storage Tank Program

918 E. Divide Ave., 3<sup>rd</sup> Floor

Phone: 701-328-5166 Fax: 701.328.5200 – Website: [deq.nd.gov/wm](http://deq.nd.gov/wm)

Revised 12/2014

Gasoline or ethanol-blended gasoline dispensed must have the octane<sup>1</sup> and ethanol blend posted (labeled) on the dispenser's front panel in a type not less than one inch [2.54 centimeters] high.

For ethanol-blended gasoline dispensed that consists of one percent or more by volume of ethanol, the dispenser shall bear the ethanol information. Dispensers posted (labeled) with the information that the ethanol-blended gasoline being dispensed is "Up To 10% Ethanol" must contain between 1% to 11% ethanol by volume or dispensers posted (labeled) with "10% Ethanol" must contain between 9% to 11% ethanol by volume.

Octane and ethanol-blended labels must be posted (labeled) in a position that is clear and conspicuous from the driver's position. Octane of all unleaded and leaded gasoline or alcohol-blended gasoline offered for retail sale must be at **least** eighty-seven.

No dealer may sell ethanol-blended gasoline unless the dispensing unit AND any price advertising bear the name of the alcohol blended with the gasoline.

Labeled Octane	Minimum Requirement	Posted (labeled)
87	86.3	"unleaded"
88	87.3	
89	88.3	"super", "plus", or "midgrade"
89.5	88.8	
90	89.3	"premium", "supreme", or "high test".
91	90.3	
92	91.3	
93	92.3	



The North Dakota Petroleum Product Testing Rules can be found at <https://www.legis.nd.gov/information/acdata/pdf/33.1-34-01.pdf>

