



**UST CATHODIC PROTECTION SYSTEM EVALUATION**  
**IMPRESSED CURRENT TYPE**  
 NORTH DAKOTA DEPARTMENT OF ENVIRONMENTAL QUALITY  
 DIVISION OF WASTE MANAGEMENT  
 SFN 60640 (6-2019)

4201 Normandy St., 2nd Floor  
 Bismarck, ND 58503-1324  
 Telephone: 701-328-5166  
 Fax: 701-328-5200  
<https://deq.nd.gov/wm>

Clear Form

**Instructions:** Within 30 days, send completed form to:

**North Dakota Department of Environmental Quality**  
**Division of Waste Management**  
**4201 Normandy Street 2nd Fl**  
**Bismarck ND 58503-1324**

ND UST ID Number

- All reports must be submitted regardless of results (pass, fail, or inconclusive).
- Incomplete, unsigned, or illegible forms will not be accepted and will be returned.

**1. UST FACILITY**

**2. UST OWNER/OPERATOR**

Name			Name		
Address			Address		
City	State	ZIP Code	City	State	ZIP Code
County	Telephone Number		County	Telephone Number	
Name of Contact		Telephone Number	Name of Contact		Telephone Number

**3. CATHODIC PROTECTION (CP) TESTER INFORMATION AND QUALIFICATIONS**

Name of Tester		Name of Company	
Address		City	State ZIP Code
Telephone Number	E-mail Address		
National Association of Corrosion Engineers (NACE) International Certification Number		Steel Tank Institute (STI) Certification Number	

**4. TEST REQUIREMENTS**

Reason Test Was Conducted (check one)

Routine - 3 year     
  Routine - within 6 months of install     
  30-day re-survey after fail     
  Re-survey within 6 months of repair/modification

**DATE NEXT SURVEY MUST BE CONDUCTED BY:** \_\_\_\_\_ (required within 6 months of installation/repair and every 3 years)

**5. EVALUATION**

CP Tester's Evaluation (check one)

**Pass**      All protected structures at this facility pass the CP survey and the continuity survey indicates all protected structures are isolated. It is judged that adequate CP has been provided to the UST system. (Complete Sections 7 and 8.)

**Fail**      One or more protected structures at this facility fail the CP survey, and it is judged that adequate CP has not been provided to the UST system. (Complete Sections 7 and 8.)

**Inconclusive**      The remote and the local do not both indicate the same test result on all protected structures (both pass or both fail), or the continuity survey indicates continuous or inconclusive results when compared to non-protected structures, the survey must be evaluated by a corrosion expert. (Corrosion expert to complete Section 6.)

**Date CP Test Performed:** \_\_\_\_\_

Name of Facility	Test Date
------------------	-----------

**6. CORROSION EXPERT'S EVALUATION (if applicable)**

A Corrosion Expert is needed to evaluate certain metal structures. See Appendix A at the end of this form for more information.

**Pass** All protected structures at this facility have been judged that adequate CP is provided to the UST system.

**Fail** One or more protected structures at this facility fail the CP survey and it is judged that adequate CP has not been provided to the UST system.

Name of Corrosion Expert	Telephone Number
Name of Corrosion Company	
NACE Int./PE Certification	NACE Int./PE Certification Number
Signature of CP Expert	Date

**7. EVALUATION CRITERIA**

Criteria Applicable to Evaluation (check all that apply)

**850 Off** Structure-to-soil potential more negative than -850 mV with the protective current momentarily interrupted. ("Instant Off")

**100 mV** Structure tested exhibits at least 100 mV of cathodic polarization.

**8. ACTION REQUIRED**

Action Required as a Result of this Evaluation (check only one)

**None** CP is adequate. No further action is necessary at this time. Test again by no later than the date in Section 4.

**Retest** CP may not be adequate. Retest within 30 days to determine if passing results can be achieved. (Retests may occur only if all intended protected structures are continuous with each other.)

**Repair and Retest** CP is not adequate. Repair/modification is necessary within the next 60 days; or permanently close the tank system.

**9. IMPRESSED CURRENT RECTIFIER DATA**

Name of Rectifier Manufacturer		Rated DC Output:		Volts	Amps		
Model		Rectifier Serial Number					
Rectifier output as designed or lastly recommended (if available):		Volts		Amps			
Event	Date (mm/dd/yyyy)	Tap Settings		DC Output		Hour Meter	Comments
		Course	Fine	Volts	Amps		
"As Found"							
"As Left"							

*Note: If rectifier output settings are modified, a corrosion expert must be consulted first and approve the modifications by signing Section 6.*

Name of Facility	Test Date
------------------	-----------

**10. IMPRESSED CURRENT POSITIVE AND NEGATIVE CIRCUIT MEASUREMENTS (output amperage)**

Complete if the system is designed to allow such measurements (e.g., individual lead wires for each anode are installed and shunts are present).

Circuit	1	2	3	4	5	6	7	8	9	10	Total Amps
Anode (+)											
Tank/Pipe (-)											

**11. CP SYSTEM REPAIRS AND/OR MODIFICATION INFORMATION**

Date of "Failing" Test	Date of Repair	Name of Repair Company
Name of Lead Repair Technician		Telephone Number
Certification of Repair Technician (check all that apply) <input type="checkbox"/> Steel Tank Institute <input type="checkbox"/> NACE		<b>Note:</b> submit failing test results with this report
Description of Repairs (check all that apply)		
<input type="checkbox"/> 1. Anodes for an impressed current system were added or replaced <input type="checkbox"/> 2. Repair or replacement of anode header cables were needed <input type="checkbox"/> 3. Continuity was not established between all protected structures <input type="checkbox"/> 4. Rectifier was repaired or replaced <input type="checkbox"/> 5. Rectifier output was modified (explain in "remarks/other" below).		<i>Repairs/modifications must be designed by a "corrosion expert". Attach corrosion expert's design specifications.</i>  <i>Retests after repairs/modifications are made must be evaluated by the corrosion expert to assure the system is functioning properly (Section 6 must be signed by expert).</i>
Remarks/Other		

**12. IMPRESSED CURRENT STRUCTURE TO SOIL POTENTIAL SURVEY**

- **Half Cell Placement (testing) on frozen soil, concrete, asphalt, or other paving materials is not acceptable.**
- The half cell must be placed locally in the soil directly over the structure being tested. **A minimum of three half cell locations per tank, and three half cell locations per piping run** are required. The three locations must be as evenly distributed over the protected structure, and as far away from any active anode as practical.
- When testing flex connectors in contact with an electrolyte, **one test point is required for each flex connector** with the halfcell placed locally in the soil directly over the flex connector being tested.
- Both "ON" and "Instant Off" potential readings are required at each half cell placement. Each half cell location must meet the "Instant Off" potential of -850 mV or more negative, or the 100 mV polarization criterion must be satisfied in order to pass.
- Check polarity (+/-) when taking readings and be sure to record them properly.

Describe Soil Type(s) of Local Reference Cell Placements:
-----------------------------------------------------------





Name of Facility	Test Date
------------------	-----------

**14. DESCRIPTION OF UST SYSTEM**

Tank/ Pipe No.	Product	Capacity (Gallons)	Tank Type <sup>1</sup>	Piping Type <sup>2</sup>	Metal Segments at Tank Sump <sup>3</sup>	Metal Segments at Dispenser <sup>3</sup>
1						
2						
3						
4						
5						
6						
7						
Ex:	<i>Premium</i>	<i>10,000</i>	<i>SW Bare Steel</i>	<i>SW Fiberglass</i>	<i>Bonded to IC System</i>	<i>In Containment</i>

1. Indicate if tank is Double Wall (DW) or Single Wall (SW). Also indicated type (e.g., steel, fiberglass, sti-P3®, composite etc.). Also indicate if tank is compartmental if applicable.
2. Indicate if piping is Double Wall (DW) or Single Wall (SW). Also indicate type (e.g., coated steel, fiberglass, galvanized, flex, etc.).
3. Indicate how metal segments such as flex connectors or metal pipe segments are protected from corrosion (e.g., isolated, booted, bonded, in containment, etc.).

**15. UST FACILITY SITE DRAWING**

Attach detailed drawing or use the space provided to draw a sketch of the UST and CP systems. At a minimum, you should indicate the following: All tanks, piping and dispensers; Location of anodes and wires if known; All buildings and streets; Location of CP test stations; Each reference cell placement must be indicated by a code (e.g., 1,2, T-1,) corresponding with the appropriate test in Section 12 of this form. If supplemental anodes are added to the tank system, indicate number, size, location and depth of the new anodes. **An evaluation of the CP system is not complete without an acceptable site drawing.**

## **APPENDIX A - SUPPLEMENTAL GUIDELINES FOR CORROSION PROTECTION**

### **Corrosion Expert's Evaluation**

A corrosion expert is anyone who is NACE International certified as a "Corrosion Specialist" or "Cathodic Protection Specialist" or is a Registered Professional Engineer who has certification or licensing that includes education and experience in corrosion control of buried or submerged metal piping systems and metal tanks.

A corrosion survey must be conducted by or evaluated by a corrosion expert when

1. Conducting repairs to metallic structures which are non-factory coated with dielectric material;
2. Adding supplemental anodes to the tanks and/or piping without following accepted industry standards;
3. The local and remote structure-to-soil potential did not result in the same outcome (both pass or both fail);
4. It is known or suspected that a stray current may be affecting the protected structure;
5. Making a repair or adding a supplemental anode to bare steel tanks/piping that is galvanically protected;
6. The metal structure being tested is poorly coated or the coating is damaged;
7. Field installing corrosion protection systems; or
8. Required by the North Dakota Department of Health.

In addition, for impressed current systems, a corrosion expert is required when

1. Installing an impressed current system;
2. Anodes were added or replaced;
3. Anode header cables are repaired or replaced;
4. Continuity was not established between all protected structures;
5. The rectifier is repaired or replaced;
6. Adjustments to the rectifier current output are made;
7. The rectifier is not working correctly; or
8. The rectifier is not operating in ranges established by a corrosion expert.

### **Testing Criteria**

The -0.85 volt current-on criterion is the most commonly used test method for evaluating coated metal tanks and piping with galvanic corrosion protection. However it cannot be used on metal structures that are poorly coated or not coated. Poorly coated or bare steel galvanic tank systems must use the -0.85 volt current-off or the 100 millivolt polarization test method and you must complete SFN 60640. If the -0.85 volt current-off or 100 millivolt polarization test method cannot be used for these systems, a corrosion expert will need to evaluate the system.